

Hopkinsville Water Environment Authority

2017 Local Limits - KYDOW Approved - 05/16/2017

Date: 05/16/2017

Pollutant	Daily Maximum Limit - mg/l	
Arsenic	0.57	
Cadmium	0.09	
Chromium, Total	2.77	
Chromium, Hexavalent	1.3	
Copper	3.22	
Cyanide, amenable	0.07	
Iron	30	
Lead	0.45	
Mercury	0.007	
Nickel	2.08	
Selenium	0.21	
Silver	0.81	
Zinc	3.98	
Compatible Pollutant	Monthly Limit - mg/l	Surcharge after limit is exceeded
Ammonia-Nitrogen (NH3)	20	\$1.45/lbs
Total Suspended Solids	350	\$0.21/lbs
BOD5	350	\$0.21/lbs